# FUJIAN EPOS ELECTRIC MACHINERY CO., LTD





ENGINE MODEL: NTA855-G1B

CURVE & DATASHEET: C-0869A

**EMEAN POWER** 

www.emeanpower.com Email: sale5@fjepos.com Phone: +86 19890349907 **WHATSAPP** 



**WECHAT** 





# CHONGQING CUMMINS ENGINE PERFORMANCE CURVE

Engine Model
NTA855-G1B
L Code Data Sheet

Curve No. **C-0869A** 

Date **2010-1-27** 

IANCE CURVE CPL Code 3550

C-0869A


**Emission Level** 


Displacement: 14L [855 in.³] Cylinders: 6 Fuel System: PT

Bore: **140mm** [5.50 in.] Speed: **1800 r/min** Cfg. Number: **D093517DX02** 

Stroke: 152mm [6.00in.] Aspiration: Turbocharged & Aftercooled

Standby Power		Prime Power		Continuous Power	
kW	HP	kW	HP	kW	HP
347	465	313	420		





	Output Power		Fuel Consumption		Fuel Rate
	HP	kW	kg/h	L/h	g/kW-h
Standby100%	465	347	74.0	89.2	213.3
100%	420	313	66.8	80.5	213.4
75%	315	235	51.2	61.7	218.1
50%	210	157	36.5	44.0	233.2
25%	105	78	20.8	25.1	265.8
10%	42	31	9.1	11.0	290.7

#### All data is based on :

- --Engine Operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer, fan, and optional driven components.
- --Engine operating with fuel corresponding to grade No.2-D per ASTM D975.
- --ISO 3046, Part1, Standard Reference Conditions of : Barometric Pressure:100kPa(29.5in.Hg);Air Temperature: 25°C (77°F) ; Relative Humidity: 30% .

STAUS FOR CURVES AND DATA:

TOLERANCE: +/-5%

**CHIEF ENGINEER:** 



# POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

<u>CONTINUOUS POWER RATING</u> is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

<u>PRIME POWER RATING</u> is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

#### **UNLIMITED TIME RUNNING PRIME POWER**

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

#### LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

#### Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

#### **Operation At Elevated Temperature And Altitude:**

The engine may be operated at:

1800 RPM up to 5000 ft. (1525 m) and 104  $^{\circ}\text{F}$  (40  $^{\circ}\text{C}) without power deration.$ 

1500 RPM up to 5000 ft. (1525 m) and 104  $^{\circ}\text{F}$  (40  $^{\circ}\text{C}) without power deration.$ 

For sustained operation above these conditions, derate by 4% per 1,000 ft. (300 m), and 1% per 10  $^{\circ}F$  (2% per 11  $^{\circ}C).$ 



## **Chongqing Cummins Engine Co. Ltd.**

### **Engine Data Sheet**

CCEC MODEL: NTA855-G1B DATA SHEET: C-0869A
NFIGURATION NO.: D093517DX02 PERFORMANCE CURVE: C-0869A
CPL NUMBER: 3550 INSTALLATION DIAGRAM: 4915105
PRIME POWER: 420 HP (313 kW) at 1800 r/min DATE: 2010/1/26

STANDBY POWER: 465 HP (347 kW) at 1800 r/min EMISSION LEVEL:

GENERAL ENGINE DATA		
Type	4-Cycle;In-line;6-Cylinder	
Aspiration		
Bore x Stroke - in. ×in. (mm×mm)		( 140 × 152 )
Displacement - in. 3(L)	855	(14)
Compression Ratio	14.0:1	
Firing Order	1-5-3-6-2-4	ŀ
Dry Weight		
Fan to Flywheel Engine - Ib. (kg)		(1300)
Heat Exchanger Cooled Engine - Ib. (kg)	3095	( 1410 )
Wet Weight	2070	( 1250 )
Fan to Flywheel Engine - Ib. (kg) Heat Exchanger Cooled Engine - Ib. (kg)		(1350) (1510)
	440.5	, ,
Moment of Inertia of Rotating Components - With FW1109 flywheel - lb.·ft.² (kg·m²)		(4.99)
Center of Gravity from Rear Face of Flywheel Housing - in.(mm)		(704)
Center of Gravity Above Crankshaft Centerline - in.(mm)	5.5	( 140 )
ENGINE MOUNTING		
Maximum Allowable Bending Moment at Rear Face of Block - lb.·ft. (N·m)	1000	( 1356 )
EXHAUST SYSTEM		
Maximum Allowable Back Pressure - in.Hg (kPa)	3.0	(10)
Standard Exhaust Pipe Diameter - in. (mm)		(127)
AIR INDUCTION SYSTEM		
Maximum Allowable Intake Air Restriction		
With Clean Filter Element - in. H <sub>2</sub> O (kPa)	15	(3.74)
With Dirty Filter Element - in. H <sub>2</sub> O (kPa)		(6.22)
Minimum Dirt Holding Capacity - g/CFM ( g/L/s )		(53)
Maximum Allowable Intake Air Temperature ΔT - °F (°C)	30	( 17 )
COOLING SYSTEM		
Coolant Capacity - Engine Only - U.S. gal (L)	5.5	( 20.8 )
- With Radiator - U.S. gal (L)		( 60.6 )
- With Heat Exchanger - U.S. gal (L)		(49.2)
Maximum Coolant Friction Head External to Engine - PSI (kPa)		(48)
Maximum Coolant Pressure (exclusive of Pressure Cap) - PSI (kPa) . Maximum Static Head of Coolant Above Engine Crank Centerline -ft. (m)		(276)
Standard Thermostat (Modulating) Range - °F (°C)		(14.0) (82 - 94)
Minimum Allowable Pressure Cap -PSI (kPa)		(48.2)
Maximum Coolant Temperature - °F (°C)		(96)
Maximum Top Tank Temperature - °F (°C)	212	( 100 )
Minimum Top Tank Temperature - °F (°C)		(71)
Maximum Allowable Top Tank Temperature for Standby / Prime Power - °F (°C)		(104/100)
Minimum Recommended Top Tank Temperature - °F (°C)		(71)
Minimum Coolant Expansion Space - % of System Capacity	5	(40)
Minimum Coolant Makeup Capacity - U.S. gal (L)	1.1 15	(4.2)
Maximum Inlet Restriction at Raw Water Pump - in.Hg (kPa)		( 103 ) ( 34 )
maximam milet rectification at reason valor rump - ming (kir a)	10	( 54 )

Maximum Raw Water Pump Initial Suction Lift- ft. (m)	3.05 2 4	( 10 ) ( 51 ) ( 28 )	
LUBRICATION SYSTEM  Oil Pressure @ Idle Speed - PSI (kPa) @ Governed Speed - PSI (kPa)  Maximum Allowable Oil Temperature - °F (°C)  Maximum Oil Consumption - U.S.qt./h (L/h)  Oil Pan Capacity - Low / High - U.S. gal. (L)  Total System Capacity - U.S. gal. (L)  Angularity of Oil Pan - Front Down/Front Up/Side to Side	250 0.25 7.5 / 9.5 10.2	( 38.6 )	
FUEL SYSTEM  Type Injection System			
With Clean Fuel Filter - in.Hg (kPa) With Dirty Fuel Filter - in.Hg (kPa)  Maximum Allowable Head on Injector Return Line	4.0 8.0	( 13.5 ) ( 27.1 )	
With Check Valve - in.Hg (kPa) Without Check Valve - in.Hg (kPa).  Minimum Fuel Supply Line Size - in. (mm).  Minimum Fuel Return Line Size - in. (mm).  Maximum Fuel Pump Supply - U.S.gal/h (L).  Fuel Rail Pressure - PSI (kPa).  Maximum Fuel Temperature °F (°C).	6.5 2.5 0.625 0.5 93 203 160	(22.0) (8.5) (16) (13) (352) (1399.5) (71)	
ELECTRICAL SYSTEM  Minimum Recommended Battery Capacity ( 24V )  Cold Soak (No Load) - CCA	900 320 900 320		
Maximum Allowable Resistance of Cranking Circuit - ohm	0.002 24 35		
PERFORMANCE DATA  Idle Speed - r/min		( 509 )	

#### All data is based on:

- --Engine Operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer, fan, and optional driven components.
- --Engine operating with fuel corresponding to grade No.2-D per **ASTM D975**.
- --ISO 3046, Part1, Standard Reference Conditions of : Barometric

Pressure:100kPa(29.5in.Hg); Air Temperature: 25°C (77°F); Relative Humidity: 30%.

--This Data Sheet includes both air-cooled (Fan/Radiator) & raw water cooled (Heatexchanger/Raw Water Pump) type engine.

	Prime Power		Standby Power	
	60Hz		60Hz	
Governed Engine Speed - r/min	ne Speed - r/min 1800		1800	
Gross Engine Power Output - HP (kW)	420	(313)	465	(347)
Torque lb.·ft. (N·m)	1225	(1661)	1358	(1841)
Brake Mean Effective Pressure - PSI (kPa)	216	(1490)	239	(1652)
Piston Speed - ft./min (m/s)	1799	(9.14)	1799	(9.14)
Friction Horsepower - HP (kW)	47	(35)	47	(35)
Intake Air Flow - CFM (L/s)	950	(448)	980	(463)
Engine Water Flow - GPM (L/min.)	95	(6)	95	(6)
Raw Water Flow - GPM (L/s)	62	(3.9)	62	(3.9)
Fuel Consumption - U.S.gal/h (L/h)	21.3	(81)	23.6	(89)
Oil Flow - GPM (L/s)	42	(2.6)	42	(2.6)
Exhaust Gas Temperature (After Turbine) - °F (°C)	870	(466)	900	(482)
Exhaust Gas Flow (After Turbine) - CFM (L/s)	2435	(1149)	2570	(1213)
Air to Fuel Ratio	26.4 : 1		24.7 : 1	
Heat Radiation - BTU (kW)	2230	(39)	2470	(43)
Heat Rejection to Coolant - BTU (kW)	13360	(235)	14810	(260)
Heat Rejection to Ambient - BTU (kW)	11130	(196)	12340	(217)

Engine Model: NTA855-G1B Data Sheet: C-0869A Date: 2010/1/26

CHONGQING CUMMINS ENGINE CO. LTD. CHONGQING, CHINA, 400031